



PH. (843) 918-1192

FAX (843) 918-1204

City of Myrtle Beach
SOUTH CAROLINA
FIRE DEPARTMENT

MBFD MEMO –

Open-flame cooking devices

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family dwellings.
2. Where buildings, balconies and decks are protected by an automatic sprinkler system.

Liquefied-petroleum-gas-fueled cooking devices

LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exception: One- and two-family dwellings.